



COMMONWEALTH of VIRGINIA
DEPARTMENT OF ENVIRONMENTAL QUALITY
DRAFT PERMIT April 30, 2019
TO WITHDRAW GROUNDWATER IN THE
EASTERN SHORE GROUNDWATER MANAGEMENT AREA

Permit Number: GW0075800

Effective Date: Mo Dy, 2019

Expiration Date: Mo Dy, 2034

Pursuant to Section 62.1-256 of the Ground Water Management Act of 1992 (Chapter 25, Title 62.1 of the Code of Virginia) and the Groundwater Withdrawal Regulations (Regulations) (9VAC25-610-10 *et seq.*), the State Water Control Board (Board) hereby authorizes the Permittee to withdraw and use groundwater in accordance with this permit.

Permittee Giuse Farm, LLC

Facility Giuse Farm

Facility Address 16487 Pungoteague Rd.

Keller, VA 23401

The Permittee's authorized groundwater withdrawal shall not exceed:

11,300,000 gallons per year,
3,000,000 gallons per month,

The permitted withdrawal will be used to provide an agricultural water supply. Other uses are not authorized by this permit.

The Permittee shall comply with all conditions and requirements of the permit.

By direction of the State Water Control Board, this Permit is granted by:

Signed _____

Date _____

Director, Office of Water Supply

April 30, 2019

This permit is based on the Permittee's application submitted on December 15, 2017 and subsequently amended to include supplemental information provided by the Permittee. The following are conditions that govern the system set-up and operation, monitoring, reporting, and recordkeeping pertinent to the Regulations.

Part I Operating Conditions

A. Authorized Withdrawal

1. The withdrawal of groundwater shall be limited to the following wells identified in the table below. Withdrawals from wells not included in Table 1 are not authorized by this permit and are therefore prohibited. 9VAC25-610-140.A

Table 1

Owner Well Name	DEQ Well #	Well Depth (ft)	Screen Intervals	Aquifer*	Latitude	Longitude	Datum
Well 1	100-01679	110	100-110	To Be Determined	37° 37' 21.98"	-75° 47' 27.24"	WGS84
Well 2	100-01680	110	100-110	To Be Determined	37° 37' 20.86"	-75° 47' 27.81"	WGS84
Well 3	100-01681	155	135-155	Upper Yorktown-Eastover	37° 37' 22.92"	-75° 47' 27.00"	WGS84
Well 4	100-01682	155	140-155	Upper Yorktown-Eastover	37° 37' 23.06"	-75° 47' 27.36"	WGS84
Well 5	100-01683	155	135-155	Upper Yorktown-Eastover	37° 37' 23.35"	-75° 47' 27.89"	WGS84
Well 6	100-01684	155	135-155	Upper Yorktown-Eastover	37° 37' 23.47"	-75° 47' 27.48"	WGS84
Well 7	100-01685	60	50-60	Columbia or Upper Yorktown-Eastover	37° 37' 32.51"	-75° 47' 32.64"	WGS84
Well 8	100-01686	110	100-110	To Be Determined	37° 37' 32.78"	-75° 47' 31.29"	WGS84
Well 9	100-01687	155	135-155	Upper Yorktown-Eastover	37° 37' 20.98"	-75° 47' 27.24"	WGS84
Well 10	100-01688	110	100-110	To Be Determined	37° 37' 30.73"	-75° 47' 30.35"	WGS84
Well 11	100-01689	110	100-110	To Be Determined	37° 37' 30.49"	-75° 47' 31.64"	WGS84
Well 12	100-01690	110	95-110	To Be Determined	37° 37' 27.71"	-75° 47' 31.59"	WGS84

*Aquifer in use was estimated based on the USGS Eastern Shore Hydrogeologic Framework and will be updated using site-specific geophysical data collected as required by the permit.

2. Any actions that result in a change to the well operation, construction, or pump intake setting of wells included in this permit must be pre-approved by the Department of Environmental Quality (Department) in writing prior to implementing the change and a revised GW-2 Form must be submitted to the Department within 30 days after the physical construction of a well is altered or the pump intake setting has been changed. If changes are a result of an emergency, notify the Department within 5 days from the change. 9VAC25-610-140.C

B. Pump Intake Settings

1. The Permittee shall not place a pump or water intake device lower than the top of the uppermost confined aquifer that a well utilizes as a groundwater source or lower than the bottom of an unconfined aquifer that a well utilizes as a groundwater source in order to prevent dewatering of the aquifer, loss of inelastic storage, or damage to the aquifer from compaction. 9VAC25-610-140.A.6

- Pump settings in individual wells are limited as follows. Any change in the pump setting must receive prior approval by the Department.

Owner Well Name	DEQ Well #	Max Pump Setting (feet below land surface)*
Well 1	100-01679	To Be Determined
Well 2	100-01680	To Be Determined
Well 3	100-01681	125
Well 4	100-01682	125
Well 5	100-01683	125
Well 6	100-01684	125
Well 7	100-01685	To Be Determined
Well 8	100-01686	To Be Determined
Well 9	100-01687	125
Well 10	100-01688	To Be Determined
Well 11	100-01689	To Be Determined
Well 12	100-01690	To Be Determined

*Max pump settings were estimated based on the USGS Eastern Shore Hydrogeologic Framework. Following the collection of the geophysical log data required by this permit, updated site-specific maximum pump setting depths will be provided by the Department to replace these estimated limits.

C. Reporting

- Water withdrawn from each well shall be recorded consistently at the end of each month and reported to the Office of Water Supply, in paper or electronic format, on a form provided by the Department by the tenth (10th) day of each January, April, July and October for the respective previous calendar quarter. Records of water use shall be maintained by the Permittee in accordance with Part III.F, 1 through 5 of this permit. 9VAC25-610-140.A.9
- The Permittee shall report any amount in excess of the permitted withdrawal limit by the fifth (5th) day of the month following the month when such a withdrawal occurred. Failure to report may result in compliance or enforcement activities. 9VAC25-610-140.C
- The following is a summary of reporting requirements for specific facility wells:

Owner Well Name	DEQ Well #	Reporting Requirements
Well 1	100-01679	Water Use
Well 2	100-01680	Water Use
Well 3	100-01681	Water Use
Well 4	100-01682	Water Use
Well 5	100-01683	Water Use
Well 6	100-01684	Water Use
Well 7	100-01685	Water Use
Well 8	100-01686	Water Use
Well 9	100-01687	Water Use
Well 10	100-01688	Water Use
Well 11	100-01689	Water Use
Well 12	100-01690	Water Use

D. Water Conservation and Management Plan

April 30, 2019

1. The Water Conservation and Management Plan (WCMP) submitted in the application received December 14, 2019 and subsequently amended and then approved by the Department is incorporated by reference into this permit and shall have the same effect as any condition contained in this permit and may be enforced as such.
2. By the end of the first year of the permit cycle (Mo Dy, 2020) the Permittee shall submit a detailed description of their leak detection and repair program activities and documentation to the Department that these activities have been conducted. This documentation shall include frequency of the activities completed and the findings and results of the activities during the first year of the permit term. 9VAC25-610-100.B.1.b,2.b,or 3.b
3. As soon as completed but not later than the end of the second year of the permit cycle (Mo Dy, 2021), the Permittee shall submit to the Department results of a 12 month audit of the total amount of groundwater used in the distribution system and the separate amounts used for drinking and cooling. This audit report shall include the flock cycle start and end dates during the year, and any necessary changes to the leak detection and repair program or operations that affected water use. 9VAC25-610-100.B.1.b,2.b,or 3.b
4. A report on the plan's effectiveness in maintaining or reducing water use and a summary of proposed revisions to the WCMP to address any elements that can be improved based on operations to date shall be submitted by the end of years five (Mo Dy, 2024) and ten (Mo Dy, 2029) of the permit term. These reports shall include as appropriate: 9VAC25-610-140.C
 - a. Any new water saving equipment installed or water saving processes adopted;
 - b. A summary of the operation of the cooling system for the houses during the report period including what months the cooling system was operated;
 - c. Evaluation of the leak detection and repair program with a summary of any significant leaks found and repaired; and
 - d. A summary of the flock cycles and overall water use patterns for each year covered by the report.
5. If revisions or additions to the plan are necessary an updated WCMP shall be submitted to the Department for approval along with the report prior to implementation of the revised plan
6. Records of activities conducted pursuant to the WCMP are to be submitted to DEQ upon request.

E. Mitigation Plan

The Mitigation Plan approved on June 22, 2018 by the Department is incorporated by reference into this permit and shall have the same effect as any condition contained in this permit and may be enforced as such. 9VAC25-610-110.D.3.g

F. Well Tags

1. Each well that is included in this permit shall have affixed to the well casing, in a prominent place, a permanent well identification plate that records, at a minimum, the DEQ well identification number, the groundwater withdrawal permit number, the total depth of the well, and the screened intervals in

April 30, 2019

the well. Such well identification plates shall be in a format specified by the Board and are available from the Department. 9VAC25-610-140.A.12

2. Well tags shall be affixed to the appropriate well casing within 30 days of receiving the tags from the Department. The accompanying well tag installation certification form shall be returned to the Department within 60 days of receipt of the tags. 9VAC25-610-140.C

Part II Special Conditions

Pursuant to 9VAC25-610-140.B and C, the following Special Conditions apply to this permit in order to protect the public welfare, safety, and health or conserve, protect and help ensure the beneficial use of groundwater.

A. Geophysical Log Data Collection

By May 31, 2023, a complete suite of geophysical logs (Spontaneous Potential, Single Point Resistance, 16/64 Short and Long Normal, Natural Gamma at a scale of 20 ft. per inch) shall be obtained from at least 3 boreholes at the locations and depths approved by the Department during the coordination process. Given the unknown hydrogeology at the site and the known potential for significant horizontal variability, additional geophysical logs may be required as determined by the Department during the drilling work to assess the well field area. An electronic and hard copy of the geophysical logs shall be submitted to the Department within 30 days of collection to allow determination of the top and bottom of the aquifer in use. 9VAC25-610-140.C

At least two months prior to the scheduled geophysical logging, the Permittee shall notify the Department of the drilling timetable to receive any further guidance needed on performing the geophysical logging and to allow scheduling of Department staff to make a site visit during the drilling of the borehole and/or the geophysical logging. Geophysical log data collected without the oversight of the Department will not be accepted.

B. Pump Intake Determination and Reset

Within 90 days of notification of the maximum pump setting depth as determined by Department staff based on new geophysical log data obtained by the Permittee as required by the permit, the Permittee shall submit documentation from a certified well provider, or other source as accepted by the Department, that the pump intake for each production well is set above the setting stated in the notification.

C. Meter Installation Verification/Correction

If notified by DEQ through an inspection report that meters meeting the requirements set forth in Part III Condition I of this permit have not been correctly installed on each production well in such a manner as to record total withdrawals from the well including both cooling water and drinking water, the Permittee shall correct any identified meter issues within 60 days of notification.

D. Alternative Source Investigation

1. By September 30, 2023 the Permittee shall conduct an investigation of the surficial aquifer (Columbia) to evaluate the ability of the surficial aquifer to provide all or part of the water supply needs for the facility. The investigation shall include water quality and pump test data collected from a surficial aquifer test well constructed on-site with Department oversight to ensure the well is properly screened in the surficial aquifer. A geophysical log shall be obtained from the surficial aquifer test well per Part III.K of the permit unless a geophysical log collected from an existing production well is accepted by DEQ as representing the Columbia aquifer at the test well location. An existing well screened in the surficial aquifer located on or near the facility property may be used where approved by DEQ as an alternative. An existing well must have sufficient well construction information available to verify it is screened in the surficial aquifer and properly constructed in order to be considered.
2. A report on the results of the investigation shall be provided to DEQ by March 31, 2024.

Part III General Conditions

A. Duty to Comply

The Permittee shall comply with all conditions of the permit. Nothing in this permit shall be construed to relieve the permit holder of the duty to comply with all applicable federal and state statutes, regulations and prohibitions. Any permit violation is a violation of the law and is grounds for enforcement action, permit termination, revocation, modification, or denial of a permit application. 9VAC25-610-130.A

B. Duty to Cease or Confine Activity

It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the activity for which a permit has been granted in order to maintain compliance with the conditions of the permit. 9VAC25-610-130.B

C. Duty to Mitigate

The Permittee shall take all reasonable steps to avoid all adverse impacts that may result from this withdrawal as defined in 9VAC25-610-10 and provide mitigation of the adverse impact when necessary as described in 9VAC25-610-110.D.3.g. 9VAC25-610-130.C

D. Inspection, Entry, and Information Requests

Upon presentation of credentials, the Permittee shall allow the Board, the Department, or any duly authorized agent of the Board, at reasonable times and under reasonable circumstances, to enter upon the Permittee's property, public or private, and have access to, inspect and copy any records that must be kept as part of the permit conditions, and to inspect any facilities, well(s), water supply system, operations, or practices (including sampling, monitoring and withdrawal) regulated or required under the permit. For the purpose of this section, the time for inspection shall be deemed reasonable during regular

April 30, 2019

business hours. Nothing contained herein shall make an inspection time unreasonable during an emergency. 9VAC25-610-130.D

E. Duty to Provide Information

The Permittee shall furnish to the Board or Department, within a reasonable time, any information that the Board may request to determine whether cause exists for modifying or revoking, reissuing, or terminating the permit, or to determine compliance with the permit. The Permittee shall also furnish to the Board or Department, upon request, copies of records required to be kept by regulation or this permit. 9VAC25-610-130.E

F. Monitoring and Records Requirements

1. The Permittee shall maintain a copy of the permit on-site and/or shall make the permit available upon request. 9VAC25-610-130.E
2. Monitoring of parameters shall be conducted according to approved analytical methods as specified in the permit. 9VAC25-610-130.F.1
3. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. 9VAC25-610-130.F.2
4. The Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart or electronic recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit, for a period of at least three years from the date of the expiration of a granted permit. This period may be extended by request of the Board at any time. 9VAC25-610-130.F.3
5. Records of monitoring information shall include as appropriate: 9VAC25-610-130.F.4
 - a. the date, exact place and time of sampling or measurements;
 - b. the name(s) of the individual(s) who performed the sampling or measurements;
 - c. the date the analyses were performed;
 - d. the name(s) of the individual(s) who performed the analyses;
 - e. the analytical techniques or methods supporting the information, such as observations,
 - f. readings, calculations and bench data used;
 - g. the results of such analyses; and
 - h. chain of custody documentation.

G. Environmental Laboratory Certification

April 30, 2019

The Permittee shall comply with the requirement for certification of laboratories conducting any tests, analyses, measurements, or monitoring required pursuant to the State Water Control Law (§ [62.1-44.2](#) et seq.), Environmental Laboratory Certification Program (§ 2.2-1105 et seq.), Certification for Noncommercial Environmental Laboratories (1VAC30-45), and/or Accreditation for Commercial Environmental Laboratories (1VAC30-46), and

- a. Ensure that all samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- b. Conduct monitoring according to procedures approved under 40CFR Part 136 or alternative methods approved by the U.S. Environmental Protection Agency.
- c. Periodically calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals that will ensure accuracy of measurements. (1VAC30-45-20)

H. Future Permitting Actions

1. A permit may be modified or revoked as set forth in Part VI of the Regulations. 9VAC25-610-290 and 9VAC25-610-130.G
2. If a Permittee files a request for permit modification or revocation, or files a notification of planned changes, or anticipated noncompliance, the permit terms and conditions shall remain effective until the Board makes a final case decision. This provision shall not be used to extend the expiration date of the effective permit. 9VAC25-610-130.G
3. Permits may be modified or revoked upon the request of the Permittee, or upon Board initiative, to reflect the requirements of any changes in the statutes or regulations. 9VAC25-610-130.G
4. The Permittee shall schedule a meeting with the Department prior to submitting a new, expanded or modified permit application. 9VAC25-610-85
5. A new permit application shall be submitted 270 days prior to the expiration date of this permit, unless permission for a later date has been granted by the Board, to continue a withdrawal greater than or equal to 300,000 gallons in any month while an application for a renewal is being processed. 9VAC25-610-96
6. A new permit application shall be submitted 270 days prior to any proposed modification to this permit that will (i) result in an increase of withdrawal above permitted limits; or (ii) violate the terms and conditions of this permit. 9VAC25-610-96
7. The applicant shall provide all information described in 9VAC25-610-94 for any reapplication. 9VAC25-610-96.C
8. The Permittee must notify the Department in writing of any changes to owner and facility contact information within 30 days of the change. 9VAC25-610-140.C

I. Metering and Equipment Requirements

April 30, 2019

1. Each well and/or impoundment or impoundment system shall have an in-line totalizing flow meter to read gallons, cubic feet, or cubic meters installed prior to beginning the permitted use. Meters shall produce volume determinations within plus or minus 10% of actual flows. 9VAC25-610-140.A.7.b
 - a. A defective meter or other device must be repaired or replaced within 30 days.
 - b. A defective meter is not grounds for not reporting withdrawals. During any period when a meter is defective, generally accepted engineering methods shall be used to estimate withdrawals. The period during which the meter was defective must be clearly identified in the groundwater withdrawal report required by Part I, Subsection D of this permit. An alternative method for determining flow may be approved by the Board on a case-by-case basis.
2. Each well shall be equipped in a manner such that water levels can be measured during pumping and non-pumping periods without dismantling any equipment. Any opening for tape measurement of water levels shall have an inside diameter of at least 0.5 inches and be sealed by a removable plug or cap. The Permittee shall provide a tap for taking raw water samples from each permitted well. 9VAC25-610-140.A.7.e

J. Minor Modifications

1. A minor modification to this permit must be made to replace an existing well(s) or add an additional well(s) provided that the well(s) is screened in the same aquifer(s) as the existing well(s), and is in the near vicinity of the existing well(s), the total groundwater withdrawal does not increase, the area of impact does not increase, and the well has been approved by the Department prior to construction. 9VAC25-610-330.B.4 and 5
2. A minor modification to this permit must be made to combine withdrawals governed by multiple permits when the systems are physically connected as long as interconnection will not result in additional groundwater withdrawal and the area of impact will not increase. 9VAC25-610-330.B.6
3. Minor modifications to this permit must also be made to:
 - a. Change an interim compliance date up to 120 days from the original compliance date, as long as the change does not interfere with the final compliance date. 9VAC25-610-330.B.7
 - b. Allow for change in ownership when the Board determines no other change in the permit is necessary and the appropriate written agreements are provided in accordance with the transferability of permits and special exceptions. 9VAC25-610-320 and 9VAC25-610-330.B.8
 - c. Revise a Water Conservation and Management Plan to update conservation measures being implemented by the Permittee that increase the amount of groundwater conserved. 9VAC25-610-330.B.9

April 30, 2019

K. Well Construction

At least 30 days prior to the scheduled construction of any well(s), the Permittee shall notify the Department of the construction timetable and receive prior approval of the well(s) location(s) and acquire the DEQ Well number. All wells shall be constructed in accordance with the following requirements.

1. A well site approval letter or well construction permit must be obtained from the Virginia Department of Health prior to construction of the well. 9VAC25-610-130.A
2. A complete suite of geophysical logs (Spontaneous Potential, Single Point Resistance, 16/64 Short and Long Normal, Natural Gamma) shall be completed for the well and submitted to the Department along with the corresponding completion report. 9VAC25-610-140.C
3. The Permittee shall evaluate the geophysical log and driller's log information to estimate the top of the target aquifer and; therefore, a depth below which the pump shall not be set. The Permittee's determination of the top of the target aquifer shall be submitted to the Department for review and approval, or approved on site by the Department's Groundwater Characterization staff, prior to installation of any pump. 9VAC25-610-140.A.6
4. The Permittee shall install gravel packs and grout in a manner that prevents leakance between aquifers. Gravel pack shall be terminated close to the top of the well screen(s) and shall not extend above the top of the target aquifer. 9VAC25-610-140.C
5. A completed GW-2 Form and any additional water well construction documents shall be submitted to the Department within 30 days of the completion of any well and prior to the initiation of any withdrawal from the well. 9VAC25-610-140.C. The assigned DEQ Well number shall be included on all well documents. 9VAC25-610-140.C
6. In addition to the above requirements, construction of a Water Level Monitoring State Observation Well (SOW) requires:
 - a. The Permittee shall coordinate activities with the Department's Groundwater Characterization Program (GWCP) to determine the appropriate observation well location and construction schedule, along with the needed screen interval(s), and other completion details following review of geophysical logging. 9VAC25-610-140.C
 - b. Prior to preparation of bid documents for construction of the observation well, the Permittee shall notify the Department and shall include any GWCP requirements in the bid documents. At a minimum, the Department will require a pre-bid meeting with interested drilling contractors and a pre-construction meeting with the successful bidder. 9VAC25-610-140.C
 - c. Instrumentation to meet the requirements for real-time data transmission consistent with the State Observation Well Network shall be purchased by the Permittee. The Permittee shall submit a purchase order based on the Department's equipment specifications for review and approval prior to purchase of the equipment. The Permittee shall not be required to install the equipment. 9VAC25-610-140.C

April 30, 2019

7. In addition to the above requirements, construction of a Chloride Monitoring SOW requires:
- a. The Permittee shall coordinate activities with the Department's Groundwater Characterization Program (GWCP) to determine the appropriate observation well location and construction schedule, along with the needed screen interval(s), and other completion details following review of geophysical logging. 9VAC25-610-140.C
 - b. Prior to preparation of bid documents for construction of the observation well, the Permittee shall notify the Department and shall include any GWCP requirements in the bid documents. At a minimum, the Department will require a pre-bid meeting with interested drilling contractors and a pre-construction meeting with the successful bidder. 9VAC25-610-140.C
 - c. Instrumentation to meet the requirements for real-time data transmission consistent with the State Observation Well Network shall be purchased by the Permittee. The Permittee shall submit a purchase order based on the Department's equipment specifications for review and approval prior to purchase of the equipment. The Permittee shall not be required to install the equipment. 9VAC25-610-140.C
 - d. Instrumentation to meet the requirements for continuous measurement of specific conductance from multiple levels within the well screen shall be purchased by the Permittee. The Permittee shall submit a purchase order based on the Department's equipment specifications for review and approval prior to purchase of the equipment. The Permittee shall not be required to install the equipment. 9VAC25-610-140.C

L. Permit Reopening

This permit may be reopened for the purpose of modifying the conditions of the permit as follows:

- a. To meet new regulatory standards duly adopted by the Board. 9VAC25-610-140.A.11
- b. When new information becomes available about the permitted withdrawal, or the impact of the withdrawal, which had not been available at permit issuance and would have justified the application of different conditions at the time of issuance. 9VAC25-610-310.B.1
- c. When the reported withdrawal is less than 60% of the permitted withdrawal amount for a five year period. 9VAC25-610-310.B.2
- d. If monitoring information indicates the potential for adverse impacts to groundwater quality or level due to this withdrawal. 9VAC25-610-140.C

COMMONWEALTH of VIRGINIA
DEPARTMENT OF ENVIRONMENTAL QUALITY

PERMIT ISSUANCE FACT SHEET

Groundwater Withdrawal Permit Number: GW0075800

Application Date: May 7, 2018

The Department of Environmental Quality (Department or DEQ) has reviewed the application for a Groundwater Withdrawal Permit. Based on the information provided in the application and subsequent revisions, DEQ has determined that there is a reasonable assurance that the activity authorized by the permit is a beneficial use as defined by the regulations. Groundwater impacts have been minimized to the maximum extent practicable. The following details the application review process and summarizes relevant information for developing the Permit and applicable conditions.

Permittee / Legal Responsible Party

Name & Address: Giuse Farm, LLC
Giuse Farm
16487 Pungoteague Rd.
Keller, VA 23401
Phone: (713) 585-3171

Facility Name and Address

Name & Address: Giuse Farm
17105 Pungoteague Rd.
Keller, VA 23401
Phone: (713) 585-3171

Contact Information:

Name: Hoai An Tran and Kevin Vu
E-mail: Kevinvu123@yahoo.com
Phone: (713) 585-3171

Proposed Beneficial Use:

The proposed use for this withdrawal is for agriculture. Withdrawals will supply a poultry growing operation with water for cooling of chicken houses as well as for direct consumption by poultry.

Processing Dates

Processing Action	Date Occurred/Received
Pre-Application Meeting:	November 1, 2017
Application Received:	December 15, 2017
Permit Fee Deposited by Accounting:	Not Applicable
Notice of Deficiency Sent	February 22, 2018
Response to Notice of Deficiency Received:	May 14, 2018
Request for Additional Information Sent:	May 14, 2018
Response to Request for Additional Information Received:	June 4, 2018
Local Government Ordinance Form Received:	June 4, 2018
Application Complete:	June 22, 2018
Submit Request for Technical Evaluation:	December 18, 2018
Technical Evaluation Received:	February 14, 2019
Draft Permit Package Sent:	April 30, 2019
Submit Draft Permit for Public Notice:	Mo Dy, 2019
Public Notice Published:	Mo Dy, 2019
End of 30-Day Public Comment Period:	Mo Dy, 2019
Response to Public comment:	Mo Dy, 2019
Public Meeting or Hearing:	Mo Dy, 2019

Application

Application Information

Giuse Farm is a poultry farm owned by Giuse Farm, LLC. and located in Accomack County. Giuse Farm has 12 poultry houses and 12 production wells. The houses are all 66 ft. wide by 600 ft. long. The farm produces broilers. Additional information on how water is used at the farm is discussed in the basis of need section of the fact sheet.

Facility construction began in 2016, with the wells constructed between July and September of 2017. The wells were not installed and geophysical data was not collected under the guidance of Department staff. The parcel was recently transferred from KVU, LLC to Giuse Farm, LLC on June 22, 2018.

Location of Facility/Withdrawal:

Water Supply Planning Unit: Accomack & Northampton

County: Accomack County

GWMA/Aquifer: Eastern Shore/Upper Yorktown-Eastover/possibly Columbia aquifer or Exmore Paleochannel

Conjunctive Use Source: This system uses no surface water and is therefore not a conjunctive use system.

Withdrawal Use, Current Need, and Projected Demand:

Basis of Need: Poultry farms use groundwater to provide drinking water to the birds as well as to supply water to either misting systems or evaporative cooling pads designed to regulate temperatures in the house and keep the birds cool. Cooling is primarily required in summer.

Water use for poultry farms varies seasonally as well as in response to the poultry life cycle. Generally during winter, fall, and spring, facility withdrawals rise and fall in a predictable pattern every 50-60 days, or the length of time it takes to raise a flock, with increased usage primarily resulting from increased water consumption as the birds gain weight. This water use pattern starts with low water consumption volumes for chick development and peaks in the last 20-30 days as growers seek to maximize adult weight gains. Typically, farms raise around five flocks per year with this cycle repeating each time. During the summer, withdrawal volumes increase due to additional water usage for flock cooling purposes.

Water volumes used for consumption are controlled by a computer system that provides water to the drinker system, which provides access to water for the birds but limits spillage or excess moisture from entering the house. Avoiding excess moisture is critical to bird health and as a result careful conservation of water is already a key tenet of management in a broiler house. The computer tracks water supplied to the drinking system and records the volume. This data was maintained by some farms but in many cases was not recorded long-term. Where available, data from the computer is discussed in the historic withdrawals section of the factsheet.

The cooling systems are operated based on temperature and humidity and while usage is typically restricted to summers, operation of the cooling systems tends to vary between farms. Historically, water supplied to the cooling systems was not metered so very limited data is available on usage.

Water Demand Projection: Water demands were based on estimated drinking and cooling water amounts needed to supply all the system houses. Proposed withdrawal limits were calculated based on the total of both consumption (drinking water) and cooling. Water use for consumption was originally calculated based upon generalized numbers provided by the primary poultry provider, Tyson, as no historical data was available; however, this data appears to have overestimated usage by using a maximum daily value instead of accounting for the cyclical and season trends associated with a poultry farm. Revised calculations were later provided based upon the "Poultry Water Use Calculation" guidance provided by DEQ and using consumption figures from nearby comparable farms as a starting point.

As no data on volumes used for cooling was available from farms operating on the shore, a procedure for estimating water use for cooling was developed for use based on discussions with industry stakeholders, individual farmers, and a review of available literature. House size and cooling fan capacity were identified as the major variables determining water use for cooling poultry houses. A formula based on 1.6 gallons per year per cubic foot per minute (cfm) of cooling fan capacity was determined to be representative for the Delmarva area poultry industry. The major variable for cooling fan capacity is the width of the house as that provides for the number and size of cooling fans that can be installed. The combined total width of the houses for the facility was used as the basis to estimate cooling water use. The water use calculations are attached to the fact sheet as Fact Sheet Attachment 4. The permit requires

April 30, 2019

metering of the wells to record total water use and actual amounts used for cooling will be collected.

A small amount of water is used for general farm operation including washing equipment, cleaning houses between flocks, and occasional tree irrigation. An amount of 100,000 gallons per year was estimated for these uses.

Water demands are not expected to change as the amount requested represents the maximum capacity of the farm and no additional houses are considered in this permit. Therefore, no projections are included for this facility.

Withdrawal Volumes Requested: The applicant originally requested 34,038,000 annually and 4,464,000 monthly; however, after recalculating needs based upon the cooling calculation procedure noted above, the following withdrawal volumes were requested based upon the projected groundwater demand.

Period of Withdrawal	Actual Volume (gal.)	Volume in MGD
Maximum Monthly:	2,407,680	0.078
Maximum Annual:	11,277,156	0.031

DEQ Evaluation

Historic Withdrawals: No record of historic withdrawals was available for this facility as the facility was recently constructed. Refer to the DEQ Water Demand Projections section above for more information on how water use was estimated.

Analysis of Alternative Water Supplies: The Eastern Shore of Virginia is an area primarily served by groundwater with the majority of withdrawals coming from the three confined Yorktown-Eastover (Upper/Middle/Lower) aquifers. There is limited surface water availability with the majority of streams being too small to supply sufficient water for most purposes, larger water bodies are typically tidally influenced, and water quality concerns have limited the development of these sources. Withdrawals from the surficial aquifer, or water table, are one viable alternative to withdrawals from the confined system. While withdrawals from the surficial aquifer can present additional water quality challenges in the form of iron forming bacteria and increased vulnerability to surface contaminants, it may be viable in some locations where capacity and quality are sufficient. In general, drinking water for poultry must be of higher quality than the cooling water. In most cases, site-specific data will be necessary to determine the viability of the surficial aquifer and to determine what portions of the use it can supply.

Public Water Supply: The proposed withdrawal does not contain a public water supply component.

Water Supply Plan Review: A Water Supply Planner coordination request was sent on September 10, 2018 and a response was received on January 9, 2019. The response noted several key items.

The Accomack County Regional Water Supply Plan (Plan) includes irrigating agricultural facilities using both groundwater and surface water, with current permitted amounts sufficient to meet demands into 2040. The plan, however, does not include existing poultry farms in their

April 30, 2019

assessments. While the seafood industry could also show future growth in the region, Section 4.0 of the ANPDC Groundwater Management Plan details industrial water for seafood and poultry processing, noting over 90% of industrial groundwater usage is related to poultry processing. WSP Staff note existing water quality concerns for surface waters and no significant water surpluses or sources in Accomack County to serve as alternative sources. Additionally, WSP staff reviewed the current alternatives under consideration, such as water table wells, and noted that the ability of the National Resources Conservation Service's (NRCS) Environmental Quality Incentives Program (EQIP) program to fund such efforts is currently unknown. The current lack of inclusion of poultry in the region's plan, existing water quality and alternative source concerns, and the unknown status of funding for alternative development underlines potential regional resource concerns to be addressed in future planning efforts.

DEQ Recommended Withdrawal Limits: The recommended withdrawal limits are based on the total of both consumption (drinking water) and cooling. Water use for consumption was evaluated based on data from a comparable farm. The consumption data from a comparable farm, Holland Farm, was provided and DEQ staff reviewed the data and determined it provided a reasonable basis for estimating monthly and annual consumption for the facility.

DEQ staff evaluated the volumes requested for cooling and determined they were accurately calculated using the procedure discussed in more detail above. Given the lack of data available for evaluating poultry water use, DEQ believes the methods employed are conservative enough to provide sufficient water for the farm to continue operation while still providing a reasonable limit for the permits. It is expected that as more metered data becomes available, withdrawal limits may be reduced in cases where actual water use is significantly lower than the permit limits.

Withdrawal limits were rounded to nearest hundred thousand in accordance with DEQ's April 6, 2015 "Rounding Memo". DEQ recommends the following withdrawal volumes based upon evaluation of the groundwater withdrawal permit application.

Period of Withdrawal	Actual Volume (gal.)	Volume in MGD
Maximum Monthly:	3,000,000	0.01
Maximum Annual:	11,300,000	0.031

Technical Evaluation: Aquaveo, LLC performed a technical evaluation of the application for the Department based on the VAHydroGW-ES model. As an aquifer pump test was not performed, the properties from the VAHydroGW-ES model were used to simulate the potential drawdown resulting from the proposed withdrawal. The model uses a base simulation which includes all existing permits (except the applicant wells) operating at their 2017 maximum annual withdrawal limit allowed under the terms of their permit for all Ground Water Management Area (GWMA) permit holders. This base simulation is then executed for 50 years. A second 50-year simulation was then conducted using the VAHydroGW-ES model with the applicant's proposed withdrawals added to the base simulation to simulate drawdown resulting from the applicant's wells using the proposed withdrawal volumes. The objectives of this evaluation were to determine the areas of any aquifers that will experience at least one foot of water level decline due to the proposed withdrawal (the Area of Impact or AOI), to determine the potential for the proposed withdrawal to cause salt-water intrusion, and to determine if the proposed withdrawal meets the 80% drawdown criteria. A summary of the results of the evaluation are provided below and the full technical

April 30, 2019

evaluation is attached to this fact sheet as Attachment 1.

Aquaveo, LLC reviewed and compared simulated 2017 water levels from the reported use to USGS measured water levels in observation wells closest to the applicant's withdrawal for the same year for the Upper, Middle, and Lower Yorktown-Eastover aquifers. Comparing the VAHydroGW-ES 2017 Historic Use Water Level with the USGS Network Well 2017 Water Level provides a method for judging the accuracy of the VAHydroGW-ES model. They noted that the water levels obtained from the regional observation networks are 2-3 ft. higher to 6 feet lower for the Upper and Middle Yorktown-Eastover aquifers and approximately 8 ft. higher to 7 ft. lower in the Lower Yorktown-Eastover. Aquaveo also noted that the observed water levels in all three aquifers exhibit yearly fluctuations in water levels of approximately 2 to 5 ft. in the Upper and 2 to 10 ft in the Middle and Lower. Water levels simulated by the VAHydroGW-ES do not fluctuate in the same manner because the pumping and recharge simulated in the model for any given year are averaged over the year and entered in the model as the average value for the year. Aquaveo concluded that while there are some variations between the observed and simulated water levels, the fluctuations and general patterns observed in the USGS wells are simulated by the VAHydroGW-ES model and the water levels from the two sources are in general agreement. Differences between observed and simulated water levels will be noted and addressed during the next calibration of the VAHydroGW-ES model.

The potential for adverse changes to water quality due to increases salinity resulting from the proposed withdrawal was evaluated using transient, density-dependent, SEAWAT simulations using the VAHydroGW-ES. The results indicated that no model cells simulate an increase in chloride concentration greater than 20 mg/L due to the proposed withdrawal. Therefore, the VAHydroGW-ES model results do not indicate the potential for reduced water quality.

The results of the VAHydroGW-ES simulations predict areas of impact due to the proposed withdrawal in the Upper, Middle, and Lower Yorktown-Eastover aquifers. The Area of Impact (AOI), or the area in which the withdrawal is expected to result in a drawdown of at least 1 foot, extend a maximum distance of approximately 0.08 miles from the production centers in the Upper, Middle, and Lower Yorktown-Eastover aquifers. As the AOI extends beyond the property line, a mitigation plan is required and will be incorporated into the permit. The modeled area of impact determines the area in which the facility must evaluate any impacts according to the process laid out in the mitigation plan. It is noted that the Exmore Paleochannel is noted in the model at approximately 1.5 miles south from the Giuse Farm wells, and therefore did not produce an AOI for this evaluation.

With the inclusion of the proposed withdrawal, the model simulated water levels at -1.1, 6.8, and 7.2 ft. msl for the Upper, Middle, and Lower Yorktown-Eastover aquifers, respectively. The 80% drawdown criterion allows the potentiometric water level (based on the critical surface elevation calculated from the VAHydroGW-ES data) to be reduced to -65.5, -120.8, and 156.0 ft. msl for the Upper, Middle, and Lower Yorktown-Eastover aquifers, respectively. Therefore, the water levels in the VAHydroGW-ES cell containing the applicant wells for each confined aquifer are not simulated to fall below the critical surface. Additionally, no new VAHydroGW-ES cells are simulated to have water levels below the critical surface. Therefore, this withdrawal is within the limits set by the 80% drawdown criterion.

Aquaveo, LLC concluded that the proposed withdrawals meet technical criteria for permit issuance. Maps of the AOIs are included in the attached Mitigation Plan.

Part I Operating Conditions

Authorized Withdrawals:

Owner Well Name	DEQ Well #	Aquifer*	Type	Max Pump Setting (ft. bls)*
Well 1	100-01679	To Be Determined	Production	To Be Determined
Well 2	100-01680	To Be Determined	Production	To Be Determined
Well 3	100-01681	Upper Yorktown-Eastover	Production	125
Well 4	100-01682	Upper Yorktown-Eastover	Production	125
Well 5	100-01683	Upper Yorktown-Eastover	Production	125
Well 6	100-01684	Upper Yorktown-Eastover	Production	125
Well 7	100-01685	Columbia or Upper Yorktown-Eastover	Production	To Be Determined
Well 8	100-01686	To Be Determined	Production	To Be Determined
Well 9	100-01687	Upper Yorktown-Eastover	Production	125
Well 10	100-01688	To Be Determined	Production	To Be Determined
Well 11	100-01689	To Be Determined	Production	To Be Determined
Well 12	100-01690	To Be Determined	Production	To Be Determined

*Max pump settings and the aquifer in use were estimated based on the USGS Eastern Shore Hydrogeologic Framework and will be updated using site-specific geophysical data collected as required by the permit.

Apportionment:

Apportionment of withdrawals is expected to be fairly equally spread across all facility wells and the permit does not include apportionment limits. Further evaluation of aquifer tops and aquifers in use will be conducted during the upcoming permit term as additional geophysical information becomes available. Limits on the apportionment may be necessary in the future if portions of the withdrawal are found to be supplied by the Columbia aquifer or a paleochannel.

Additional Wells:

There are no additional observation, abandoned, or out of service wells associated with this facility.

Pump Intake Settings:

Pump intakes for Wells # 1, #2, #6, #8, #10, and #11 are reported to be set at 90 ft bls. Pump intakes for Wells #3, #4, #5, and #9 are reported to be set at 115 ft bls. The pump intake for Well #7 is reported to be set at 50 ft bls, with the pump intake for Well #12 reported to be set at 80 ft bls. All the pump intake depths are documented on the GW-2 well completion forms.

No geophysical log data was available for this site and therefore aquifer elevation for the top of the aquifer in use was estimated using the USGS Eastern Shore Hydrogeologic Framework. Once

April 30, 2019

geophysical log data is obtained in compliance with the permit, DEQ geologists will determine the top of the aquifer in use, which will be the pump intake limit above which the pumps must be set. The permittee will have 90 days to ensure all pumps meet the intake limits once notified of the limits by DEQ.

Withdrawal Reporting:

Groundwater withdrawals are to be recorded monthly and reported quarterly.

Water Conservation and Management Plan:

A Water Conservation and Management Plan (WCMP) meeting the requirements of 9VAC25-610-100.B was submitted and reviewed as part of the application process. The accepted Plan is to be followed by the permittee as an operational Plan for the facility/water system.

- A detailed description of the leak detection and repair program activities and documentation to the Department that these activities have been conducted is due by the end of the first year of the permit term (Mo Dy, 2020).
- A result of a 12 month audit of the total amount of groundwater used in the distribution system and the amounts for drinking and cooling water, documentation of the flock cycle start and end dates, and any necessary changes to the operation affecting water use is due by the end of the second year of the permit term (Mo Dy, 2021).
- A report on the plan's effectiveness in maintaining or reducing water use amounts needed, including revisions to those elements of the WCMP that can be improved and addition of other elements found to be effective based on operations to date shall be submitted by the end of years five (Mo Dy, 2024) and ten (Mo Dy, 2029) of the permit term.

Mitigation Plan:

The predicted AOI resulting from the Technical Evaluation extends beyond the property boundaries in the Upper Yorktown-Eastover. Given this prediction, a Mitigation Plan to address potential claims from existing well owners within the predicted area of impact is included in the permit by reference.

Well Tags:

Well tags will be transmitted with the final permit.

Part II Special Conditions

Geophysical Log Data Collection:

Geophysical log information is needed to evaluate the top of the aquifer in use and the regulatory permitted pump intake limit, and to determine whether the current pump settings meet regulatory limitations. The Department requires collection of a geophysical log for each new well to be included in a Groundwater Withdrawal Permit. Given the large number of wells associated with poultry facilities, the Department agreed to work with applicants that had constructed wells prior to application to allow for a reduced number of geophysical logs required to represent the wells keeping in mind the need to evaluate

April 30, 2019

lateral variation in the hydrogeology. The Permittee must contact DEQ at least two months prior to scheduling the geophysical logs to allow for Department scheduling.

The collection of geophysical log data requires a borehole to be drilled at least to the depth of the deepest facility well, or an alternative depth at the discretion of the Department, and the logging equipment run down the full depth of the hole. Geophysical logging is to include 16"/64" Normal, Single Point, Self-Potential, and Natural Gamma at a scale of 20 feet per inch. Collection of a full suite of geophysical logs and a drillers log is required by May 31, 2023 at a minimum of 3 locations with the locations and depths approved by DEQ. Additional geophysical log locations may be required by Department staff as warranted depending on site hydrogeology to evaluate lateral variation in the aquifer top elevations or the extent/presence of a paleochannel in the well vicinity. These logs will be used to represent the remaining facility wells. Department staff must be present for the geophysical logging to evaluate the log and well cuttings.

Pump Intake Determination and Reset:

Within 90 days of notification of pump intake limits by the Department based on the geophysical data, the permittee shall ensure all pump intakes are set above the identified limits. The Permittee is to notify the Department of the work schedule and to submit written documentation of the pump setting within 30 days of the work.

Meter Installation/Verification:

In cases where meters are found to be incorrectly installed or otherwise failing to capture the total water use of each well, DEQ will notify the permittee of such via an inspection report and the permittee shall correct any meter issues within 60 days.

Alternative Source Investigation:

The facility is supplied by wells screened in the confined Upper Yorktown-Eastover aquifer. The confined aquifer system on the Eastern Shore is considered to be of higher quality than the surficial (water table) aquifer and is the potable water supply for the majority of the Eastern Shore. The regulation requires the lowest quality water available be applied to the permitted use. While the application states generally that the surficial aquifer would not be viable, site specific investigation is necessary to evaluate the surficial aquifer quality and availability. By September 30, 2023, an alternative source investigation must be completed and the results submitted to DEQ by March 31, 2024 for review and acceptance. The investigation shall provide pump test and water quality data from a test or production well screened in the surficial aquifer on the facility site as well as conclusions on the capability of the surficial aquifer to supply all or part of the water needs for the facility.

Part III

General Conditions

General Conditions are applied to all Groundwater Withdrawal Permits, as stated in the Groundwater Withdrawal Regulations, 9VAC25-610-10 *et seq.*

Public Comment

The following sections will be completed after close of the public comment period.

Relevant Regulatory Agency Comments:

Summary of VDH Comments and Actions: This facility is not a public water supply so soliciting comments from VDH was not required.

Public Involvement during Application Process:

Local and Area wide Planning Requirements: The Accomack County Administrator indicated on April 24, 2018 that the facility's operations are consistent with all ordinances.

Public Comment/Meetings: The public notice was published in the Eastern Shore Post on Mo Dy, 2019. The public comment period ran from Mo Dy, 2019 to Mo Dy, 2019.

Changes in Permit Part II Due to Public Comments

Changes in Permit Part III Due to Public Comments

Staff Findings and Recommendations

Based on review of the permit application, staff provides the following findings.

- The proposed activity is consistent with the provisions of the Ground Water Management Act of 1992, and will protect other beneficial uses.
- The proposed permit addresses minimization of the amount of groundwater needed to provide the intended beneficial use.
- The effect of the impact will not cause or contribute to significant impairment of state waters.
- This permit includes a plan to mitigate adverse impacts on existing groundwater users.

Staff recommends Groundwater Withdrawal Permit Number GW0073800 be issued as proposed.

Attachments

- 1. Technical Evaluation**
- 2. Water Conservation Plan**
- 3. Mitigation Plan**
- 4. Water Use Calculation Worksheet**
- 5. Public Comment Sheet**

Approved: _____
Director, Office of Water Supply

Date: _____

**COMMONWEALTH of VIRGINIA
DEPARTMENT OF ENVIRONMENTAL QUALITY**

TECHNICAL EVALUATION FOR PROPOSED GROUNDWATER WITHDRAWAL

Date: December 14, 2018

Application /Permit Number: GW0075800

Owner / Applicant Name: Hoai An Tran

Facility / System Name: Giuse Farm

Facility Type: Agriculture – Poultry Farm

Facility / System Location: Accomack County

The Commonwealth of Virginia’s Groundwater Withdrawal Regulations (9VAC25-610-110(D) state that, for a permit to be issued for a new withdrawal, to expand an existing withdrawal, or reapply for a current withdrawal, a technical evaluation shall be conducted. This report documents the results of the technical evaluation conducted to meet the requirements for the issuance of a permit to withdrawal groundwater within a Groundwater Management Area as defined in (9VAC25-600-10 et seq.).

This evaluation determines the:

- (1) The Area of Impact (AOI): The AOI for an aquifer is the areal extent of each aquifer where one foot or more of drawdown is predicted to occur as a result of the proposed withdrawal.
- (2) Water Quality: The potential for the proposed withdrawal to cause salt water intrusion into any portions of any aquifers or the movement of waters of lower quality to areas where such movement would result in adverse impacts on existing groundwater users or the groundwater resource as per (9VAC25-610-110(D)(2), and
- (3) The Eighty Percent Drawdown (80% Drawdown): The proposed withdrawal in combination with all existing lawful withdrawals will not lower water levels, in any confined aquifer that the withdrawal impacts, below a point that represents 80% of the distance between the land surface and the top of the aquifer at the points where the one-foot drawdown contour is predicted for the proposed withdrawal as per 9VAC25-610-110(D)(3)(h).

Summary of Requested Withdrawal:

General:

In response to the Department of Environmental Quality’s (DEQ) Compliance Assistance Framework initiative, a cohort of poultry farms in Accomack County were identified as potentially requiring a groundwater withdrawal permit (GWWP). The farms primarily grow broilers which are processed by several poultry integrators located in the area. These farms use groundwater to provide drinking water to the birds as well as to supply water to either misting systems or evaporative cooling pads which cool the birds. Cooling is primarily required in summer. Most wells associated with poultry farms in Accomack County are screened in either the upper, middle, or lower Yorktown-Eastover aquifers. The use of the Columbia (water-table) aquifer is being investigated by the industry and this aquifer may be used in the future to augment withdrawals from confined aquifers where possible.

Water use for poultry farms varies seasonally as well as in response to the poultry life cycle. Generally during winter, fall, and spring, facility withdrawals rise and fall in a fairly predictable pattern every 50-60 days, with usage primarily resulting from water consumption. This pattern starts with low water

consumption volumes for chick development and maxes out in the last 20-30 days as breeders seek to maximize adult weight gains. Typically, farms raise around five flocks per year with this cycle repeating each time. During the summer, withdrawal volumes increase due to additional water usage for flock cooling purposes. A few farms have additional sanitary and other agricultural uses (crops/other livestock).

Facility Specific:

Giuse Farm has 12 poultry houses and 8 production wells. All 12 houses are 66 feet wide by 600 feet long. It should be noted that these 12 houses are adjacent to 12 very similar poultry houses on a separate but neighboring property that is registered to Van Tran Farm (GW0075400). Proposed withdrawal limits were calculated based on the total of both consumption (drinking water) and cooling. Water use for consumption was calculated based on consultant and DEQ calculation formats. Water use for cooling was calculated based on estimates established on house size and cooling fan capacity.

Volumes include additional water for onsite residential sanitary usage.

The proposed withdrawal limits and well construction details are as follows:

Proposed Withdrawal Limits:

Proposed Withdrawal Limits	
Annual Value	11,300,000 gallons (30,959 average gpd)
Monthly Value	3,000,000 gallons (96,774 average gpd)

Proposed Apportionment of Withdrawal:

Due to the well and plumbing configuration, the withdrawal will be apportioned fairly equally between the system wells with 5 of the wells withdrawing from the Upper Yorktown-Eastover and 7 of the wells withdrawing from what appears to be a Paleochannel aquifer.

DEQ Well #	Owner Well #	Aquifer	Percent of Withdrawal
100-01679 100-01680 100-01685 100-01686 100-01688 100-01689 100-01690	Well #1 Well #2 Well #7 Well #8 Well #10 Well #11 Well #12	Paleochannel	58
100-01681 100-01682 100-01683 100-01684 100-01687	Well #3 Well #4 Well #5 Well #6 Well #9	Upper Yorktown-Eastover	42

Production Well(s):

Identification	Location	Construction	Pump Intake	Source Aquifer
Owner Well Name: Well #1 DEQ Well Number: 100-01679 MPID: 373722075472701	Lat: 37° 37' 21.98" Lon: -75° 47' 27.24" Datum: WGS84 Elevation: 40	Completion Date: 7/20/2017 Screens (ft-bls): 100-110 Total Depth (ft-bls): 110	90	Paleochannel
Owner Well Name: Well #2 DEQ Well Number: 100-01680 MPID: 373721075472802	Lat: 37° 37' 20.86" Lon: -75° 47' 27.81" Datum: WGS84 Elevation: 40	Completion Date: 7/28/2017 Screens (ft-bls): 100-110 Total Depth (ft-bls): 110	90	Paleochannel
Owner Well Name: Well #3 DEQ Well Number: 100-01681 MPID: 373723075472703	Lat: 37° 37' 22.92" Lon: -75° 47' 27.00" Datum: WGS84 Elevation: 40	Completion Date: 7/24/2017 Screens (ft-bls): 135-155 Total Depth (ft-bls): 155	115	Upper Yorktown-Eastover
Owner Well Name: Well #4 DEQ Well Number: 100-01682 MPID: 373723075472704	Lat: 37° 37' 23.06" Lon: -75° 47' 27.36" Datum: WGS84 Elevation: 40	Completion Date: 8/5/2017 Screens (ft-bls): 140-155 Total Depth (ft-bls): 155	115	Upper Yorktown-Eastover
Owner Well Name: Well #5 DEQ Well Number: 100-01683 MPID: 373723075472805	Lat: 37° 37' 23.35" Lon: -75° 47' 27.89" Datum: WGS84 Elevation: 40	Completion Date: 8/10/2017 Screens (ft-bls): 135-155 Total Depth (ft-bls): 155	50	Upper Yorktown-Eastover

Owner Well Name: Well #6	Lat: 37° 37' 23.47" Lon: -75° 47' 27.48"	Completion Date: 8/6/2017	90	Upper Yorktown- Eastover
DEQ Well Number: 100-01684	Datum: WGS84 Elevation: 40	Screens (ft-bls): 135-155		
MPID: 373723075472706		Total Depth (ft-bls): 155		
Owner Well Name: Well #7	Lat: 37° 37' 32.51" Lon: -75° 47' 32.64"	Completion Date: 9/12/2017	50	Paleo channel
DEQ Well Number: 100-01685	Datum: WGS84 Elevation: 40	Screens (ft-bls): 50-60		
MPID: 373733075473307		Total Depth (ft-bls): 60		
Owner Well Name: Well #8	Lat: 37° 37' 32.78" Lon: -75° 47' 31.29"	Completion Date: 8/18/2017	90	Paleo channel
DEQ Well Number: 100-01686	Datum: WGS84 Elevation: 40	Screens (ft-bls): 100-110		
MPID: 373733075473108		Total Depth (ft-bls): 110		
Owner Well Name: Well #9	Lat: 37° 37' 20.98" Lon: -75° 47' 27.24"	Completion Date: 9/14/2017	115	Upper Yorktown- Eastover
DEQ Well Number: 100-01687	Datum: WGS84 Elevation: 40	Screens (ft-bls): 135-155		
MPID: 373721075472709		Total Depth (ft-bls): 155		
Owner Well Name: Well #10	Lat: 37° 37' 30.73" Lon: -75° 47' 30.35"	Completion Date: 9/16/2017	90	Paleo channel
DEQ Well Number: 100-01688	Datum: WGS84 Elevation: 40	Screens (ft-bls): 100-110		
MPID: 373731075473010		Total Depth (ft-bls): 110		
Owner Well Name: Well #11	Lat: 37° 37' 30.49" Lon: -75° 47' 31.64"	Completion Date: 9/19/2017	90	Paleochannel
DEQ Well Number: 100-01689	Datum: WGS84 Elevation: 40	Screens (ft-bls): 100-110		
MPID: 373730075473211		Total Depth (ft-bls): 110		

Owner Well Name: Well #12	Lat: 37° 37' 27.71" Lon: -75° 47' 31.59"	Completion Date: 10/13/2017	80	Paleochannel
DEQ Well Number: 100-01690	Datum: WGS84 Elevation: 40	Screens (ft-bls): 95-110		
MPID: 373728075473212		Total Depth (ft-bls): 110		

Geologic Setting:

The Giuse Farm wells (applicant wells) are located in southern Accomack County. The production wells are screened in the Upper Yorktown-Eastover aquifer and possible the Exmore Paleochannel. The Eastern Shore paleochannels are subsurface erosional channels where all or part of the Yorktown Formation sediments have been removed and replaced by marginal-marine deposits of Pleistocene age¹. The exact extents and depths of the paleochannels are currently being investigated by the U.S. Geological Survey (USGS). The upper portion of the Yorktown-Eastover aquifer (described in the 2006 Virginia Coastal Plain Hydrologic Framework² (VCPHF) as a combination of the Upper, Middle, and Lower Yorktown-Eastover aquifers) is composed primarily of estuarine to marine quartz sands of the Yorktown Formation of Pliocene age. The nearest USGS geologic cross section found in USGS Professional Paper 1731 is cross-section GS-GS' (see attached figure at the end of the report).

Virginia Eastern Shore Model data:

The following table lists the location of the applicant production wells within the Virginia Eastern Shore Model³ (VAHydroGW-ES).

VAHydroGW-ES Model Grid				
Well	Well Number	MPID	Row	Column
Well #1	100-01679	373722075472701	177	35
Well #2	100-01680	373721075472802	177	35
Well #3	100-01681	373723075472703	177	35
Well #4	100-01682	373723075472704	177	35
Well #5	100-01683	373723075472805	177	35
Well #6	100-01684	373723075472706	177	35
Well #7	100-01685	373733075473307	176	34
Well #8	100-01686	373733075473108	176	34
Well #9	100-01687	373721075472709	177	35
Well #10	100-01688	373731075473010	176	34
Well #11	100-01689	373730075473211	176	34
Well #12	100-01690	373728075473212	177	34

¹ Sanford, W.E., Pope, J.P., and Nelms, D.L., 2009, Simulation of groundwater-level and salinity changes in the Eastern Shore, Virginia: U.S. Geological Survey Scientific Investigations Report 2009–5066, 125 p.

² McFarland, E.R., and Bruce, T.S., 2006, The Virginia Coastal Plain Hydrogeologic Framework: U.S. Geological Survey Professional Paper 1731, 118 p., 25 pls.

³ Sanford, W.E., Pope, J.P., and Nelms, D.L., 2009, Simulation of groundwater-level and salinity changes in the Eastern Shore, Virginia: U.S. Geological Survey Scientific Investigations Report 2009–5066, 125 p.

Hydrologic Framework:

Data from the VCPHF is reported in this technical report to illustrate the hydrogeologic characteristics of the aquifers in the Virginia Eastern Shore near the applicant wells and identify major discrepancies between regional hydrogeology and site logs interpreted by the DEQ staff geologist.

The following average aquifer elevations were estimated from the VAHydroGW-ES at the model cell(s) containing the applicant production wells.

VAHydroGW-ES Average Hydrologic Unit Information		
Aquifer	Elevation (feet msl)	Depth (feet bls)
Surface	39	0
Columbia aquifer (bottom)	-24	63
Upper Yorktown-Eastover aquifer (top)	-86	125
Upper Yorktown-Eastover aquifer (bottom)	-124	163
Middle Yorktown-Eastover aquifer (top)	-154	193
Middle Yorktown-Eastover aquifer (bottom)	-181	220
Lower Yorktown-Eastover aquifer (top)	-199	238
Lower Yorktown-Eastover aquifer (bottom)	-277	316

Eastern Shore Hydrogeologic Framework Based Recommendations:

Due to a lack of geophysical borehole data, DEQ staff has reviewed available information and made the following preliminary determinations regarding the location of the aquifer tops for the following wells based upon a review of the GW-2 forms available and The Virginia Coastal Plain Hydrogeologic Framework (USGS Professional Paper 1731). Further evaluation of aquifer tops will be conducted during the upcoming permit term and as additional geophysical information becomes available.

Unit	Well #1-12 (ft-bls)
Top of the Upper Yorktown-Eastover	126
Top of the Middle Yorktown-Eastover	195
Top of the Lower Yorktown-Eastover	239

Water Level Comparison:

Below water levels retrieved from the USGS regional observation network wells are compared to the simulated water levels reported in the *Virginia Eastern Shore 2017-2018 Annual Simulation of Potentiometric Groundwater Surface Elevations of Reported and Total Permitted Use* report (the 2017-2018 report) and simulation files.⁴ This comparison is made in order to evaluate the performance of the regional model in the vicinity of the applicant wells and assess historical groundwater trends.

The 2017-2018 report provides two sets of simulated potentiometric water surface elevations. The VAHydroGW-ES model is divided into three parts. The first portion of the model simulates water levels within the Eastern Shore aquifers from 1900 through 2017 based upon historically reported pumping amounts (the “*Historic Use Simulation*”). This portion of the model has been calibrated to match water levels observed in USGS regional observation network wells situated throughout the peninsula. The water levels reported in the 2017-2018 report are based upon two separate simulations, each simulation running

⁴ See *Virginia Eastern Shore 2017-2018 Annual Simulation of Potentiometric Groundwater Surface Elevations of Reported and Total Permitted Use* report and simulation files on file with the VA DEQ.

from 2018 through 2067. The simulated pumping amount in these two simulations are based upon, 1) the average 2013-2017 reported withdrawal amount of wells in the VAHydroGW-ES model (the “*Reported Use Simulation*”) and, 2) the current (2018) maximum withdrawal amount allowed under their current permit for wells in the VAHydroGW-ES model (the “*Total Permitted Simulation*”). Both these simulations are an extension of the *Historic Use Simulation* and the water levels reported in the 2017-2018 report are the final water levels simulated at the end of the simulations (2067).

The “VAHydroGW-ES 2067 Reported Use Water Level,” reported in the tables below, is the simulated water level – 50 years from present – if all permitted pumping continued at the average 2013-2017 reported withdrawal amount for the next 50 years. And the “VAHydroGW-ES 2067 Total Permitted Water Level,” reported in the tables below, is the simulated water level – 50 years from present – if all Eastern Shore permitted wells were to pump at the maximum permitted amount allowed under their current permit for the next 50 years. Finally, the “VAHydroGW-ES 2017 Historic Use Water Level,” reported in the tables below, is the water level simulated for the year 2017 in the *Historic Use Simulation*.

The nearest USGS regional observation network wells to the applicant wells, completed in the Upper, Middle, or Lower Yorktown-Eastover aquifers, are listed in the following tables and shown in Figure 1. For the USGS regional observation network wells, average 2017 reported water levels are shown in the following tables. Simulated water levels for the Upper, Middle, and Lower Yorktown-Eastover aquifers, for the VAHydroGW-ES cells containing the USGS regional observation network wells are also shown in the following tables.




Figure 1. Nearest USGS regional observation network wells.

Comparing the VAHydroGW-ES 2017 Historic Use Water Level with the USGS Network Well 2017 Water Level provides a method for judging the accuracy of the VAHydroGW-ES. Figures 2 through 9 show graphs of the recorded water levels from the USGS observation wells listed in the following tables. These figures also show the simulated VAHydroGW-ES *Historic Use Simulation* water levels for the model cell containing each USGS well. Observing the simulated and observed water elevations together provide a second method for assessing the accuracy of the VAHydroGW-ES in the vicinity of the applicant wells.

The Upper Yorktown-Eastover VAHydroGW-ES 2017 Reported Use Water Levels are 3 feet higher to 6 feet lower than the USGS Network Well 2017 Water Levels observed in Well 64J 9 SOW 112A, Well 63J 1 SOW 113A, and Well 64K 11 SOW 108B. The water levels observed over the past approximately 40 years in each Upper Yorktown-Eastover USGS well are shown in Figures 2 through 4. The wells exhibit yearly fluctuations in water levels of approximately 2 to 5 feet. Water levels simulated by the VAHydroGW-ES do not fluctuate in the same manner because the pumping and recharge simulated in the model for any given year are averaged over the year and entered in the model as the average value for the year. Water levels for the USGS Upper Yorktown-Eastover wells are in general agreement with the water levels simulated by the VAHydroGW-ES – especially for Well 63J 1 SOW 113A. While still reasonably accurate, water levels are approximately 5 feet higher for Well 64J 9 SOW 112A and for Well 64K 11 SOW 108B, over the past four decades, when compared to those simulated by the VAHydroGW-ES.

The Middle Yorktown-Eastover VAHydroGW-ES 2017 Reported Use Water Levels are 2 feet higher to 6 feet lower than the USGS Network Well 2017 Water Levels observed in Well 64J 10 SOW 112B and Well 63J 2 SOW 113B. The water levels observed over the past 40 years in the Middle Yorktown-Eastover USGS wells are shown in Figures 5 and 6. Each well exhibits yearly fluctuations in water levels of approximately 2 to 10 feet. Water levels for the USGS Middle Yorktown-Eastover wells are in general agreement with the water levels simulated by the VAHydroGW-ES – especially for Well 63J 2 SOW 113B. The fluctuations and general patterns observed in Well 64J 10 SOW 112B are generally simulated by the VAHydroGW-ES, with water levels for Well 64J 10 SOW 112B higher by approximately 5 feet than those simulated by the VAHydroGW-ES over the past 40 years.

The Lower Yorktown-Eastover VAHydroGW-ES 2017 Reported Use Water Level is approximately 7 feet lower than the USGS Network Well 2017 Water Level observed in Well 64J 11 SOW 112C; the VAHydroGW-ES 2017 value for USGS 63J 3 SOW 113C is approximately 4 feet higher; and the 2017 VAHydroGW-ES water level is approximately 8 feet higher than the level observed in Well 64K 12 SOW 108C. The water levels observed over the past 40 years in the Lower Yorktown-Eastover USGS wells are shown in Figures 7 through 9. Each well exhibits yearly fluctuations in water levels of approximately 2 to 10 feet. Water levels for the USGS Lower Yorktown-Eastover wells are in general agreement with the water levels simulated by the VAHydroGW-ES. The fluctuations and general patterns observed in Well 64J 11 SOW 112C and Well 63J 2 SOW 113C are generally simulated by the VAHydroGW-ES. Water levels simulated by the VAHydroGW-ES are also in general agreement with those observed in Well 64K 21 SOW 108C – though the observed water levels do decline at a larger rate than those simulated.

Differences between observed and simulated water levels will be noted and addressed during the next calibration of the VAHydroGW-ES.

Upper Yorktown-Eastover Measurements	64J 9 SOW 112A	63J 1 SOW 113A	64K 11 SOW 108B
Distance from applicant wells (miles)	7.5	8.5	3.0
VAHydroGW-ES Row	215	219	161
VAHydroGW-ES Column	46	19	38
VAHydroGW-ES Land Surface Elevation (ft-msl)	21	21	44
USGS Well Land Surface Elevation (ft-msl)	30	22	47
USGS Network Well 2017 Water Level (ft-msl)	6.1	-2.1	33.5
VAHydroGW-ES 2017 Reported Use Water Level (ft-msl)	-0.2	0.8	29.4
VAHydroGW-ES 2067 Reported Use Water Level (ft-msl)	-0.4	-2	29.3
VAHydroGW-ES 2067 Total Permitted Water Level (ft-msl)	-6.7	-9.1	28.3

Middle Yorktown-Eastover Measurements	64J 10 SOW 112B	63J 2 SOW 113B
Distance from applicant wells (miles)	7.5	8.5
VAHydroGW-ES Row	215	219
VAHydroGW-ES Column	46	19
VAHydroGW-ES Land Surface Elevation (ft-msl)	21	21
Land Surface Elevation (ft-msl)	30	22
USGS Network Well 2017 Water Level (ft-msl)	6.3	-1.5
VAHydroGW-ES 2017 Reported Use Water Level (ft-msl)	-0.2	0.7
VAHydroGW-ES 2067 Reported Use Water Level (ft-msl)	-0.4	-2
VAHydroGW-ES 2067 Total Permitted Water Level (ft-msl)	-6.7	-9.1

Lower Yorktown-Eastover Measurements	64J 11 SOW 112C	63J 3 SOW 113C	64K 12 SOW 108C
Distance from applicant wells (miles)	7.5	8.5	3.0
VAHydroGW-ES Row	215	219	161
VAHydroGW-ES Column	46	19	38
VAHydroGW-ES Land Surface Elevation (ft-msl)	21	21	44
Land Surface Elevation (ft-msl)	30	22	47
USGS Network Well 2017 Water Level (ft-msl)	6.9	-3.3	12.9
VAHydroGW-ES 2017 Reported Use Water Level (ft-msl)	-0.1	0.4	20.8
VAHydroGW-ES 2067 Reported Use Water Level (ft-msl)	-0.3	-2.3	20.6
VAHydroGW-ES 2067 Total Permitted Water Level (ft-msl)	-6.6	-9.4	18.9




Figure 2. USGS Regional Observation Well 64J 9 SOW 112A, Upper Yorktown-Eastover aquifer water levels recorded from 1979 to present (well depth 135 ft bls, land surface 30 ft msl).




Figure 3. USGS Regional Observation Well 63J 1 SOW 113A, Upper Yorktown-Eastover aquifer water levels recorded from 1980 to present (well depth 120 ft bls, land surface 22 ft msl).




Figure 4. USGS Regional Observation Well 64K 11 SOW 108B, Upper Yorktown-Eastover aquifer water levels recorded from 1978 to present (well depth 180 ft bls, land surface 47 ft msl).




Figure 5. USGS Regional Observation Well 64J 10 SOW 112B, Middle Yorktown-Eastover aquifer water levels recorded from 1979 to present (well depth 210 ft bls, land surface 30 ft msl).




Figure 6. USGS Regional Observation Well 63J 2 SOW 113B, Middle Yorktown-Eastover aquifer water levels recorded from 1980 to present (well depth 225 ft bls, land surface 22 ft msl).




Figure 7. USGS Regional Observation Well 64J 11 SOW 112C, Lower Yorktown-Eastover aquifer water levels recorded from 1979 to present (well depth 313 ft bls, land surface 30 ft msl).




Figure 8. USGS Regional Observation Well 63J 2 SOW 113C, Lower Yorktown-Eastover aquifer water levels recorded from 1980 to present (well depth 290 ft bls, land surface 22 ft msl).




Figure 9. USGS Regional Observation Well 64K 21 SOW 108C, Lower Yorktown-Eastover aquifer water levels recorded from 1978 to present (well depth 284 ft bls, land surface 47 ft msl).

Aquifer Test(s):

An aquifer test has not been conducted for this system and the VAHydroGW-ES model was used to evaluate the application. The following table provides the average hydrogeologic properties assigned to the VAHydroGW-ES cell(s) containing the applicant wells

Virginia Eastern Shore Model Hydrogeologic Properties: Row 176 & 177/Column 34 & 35							
Aquifer	Top Elevation (feet msl)	Top Elevation (feet bls)	Aquifer Thickness (feet)	Horizontal Conductivity (feet/day)	Vertical Conductivity (feet/day)	Specific Storage (1/feet)	Specific Yield
Columbia	39	0	63	55	0.5	0.00001	0.15
Upper Yorktown-Eastover	-86	125	38	4	5.0	0.000004	N/A
Middle Yorktown-Eastover	-154	193	26	6	5.6	0.000004	N/A
Lower Yorktown-Eastover	-199	238	78	3	2.4	0.000004	N/A

Model Results

Evaluation of Withdrawal Impacts:

The VAHydroGW-ES model was used to simulate the effects resulting from the proposed withdrawal due to the multi-aquifer impacts. The stabilized effects resulting from the proposed withdrawal were simulated at the annual permitted withdrawal rate of 11,300,000 gallons per year (30,959 average gpd). The stabilized effects were simulated by replacing the reported use amounts in the 2017 VAHydroGW-ES Reported Use Simulation with the current maximum annual withdrawal limit allowed under the terms of their permit for all Ground Water Management Area (GWMA) permit holders. That same simulation was executed twice, once with the proposed withdrawal removed (the *baseline simulation*), and once with the proposed withdrawal added (the *proposed withdrawal simulation*). The stabilized effects of the proposed withdrawal were considered by simulating both simulations for 50 years and observing the difference in water potentiometric levels at the end of the simulations.

Area of Impact:

The area of impact (AOI) for an aquifer is the area where the additional drawdown due to the proposed withdrawal exceeds one foot. The results of the VAHydroGW-ES simulations, outlined in the preceding section, predict areas of impact in the Upper, Middle, and Lower Yorktown-Eastover aquifers. The AOI areas extend a maximum distance of approximately 0.8 miles from the production center for the Upper, Middle, and Lower Yorktown-Eastover aquifers. AOI maps for all affected aquifers are attached to this report. Currently, the Exmore paleochannel is simulated within the VAHydroGW-ES approximately 1.5 miles south of the Giuse Farm wells. As such, the Exmore paleochannel did not produce an AOI.

80 % Drawdown:

The 80% drawdown criterion was evaluated for all impacted, confined aquifers in the Virginia Eastern Shore using the VAHydroGW-ES *proposed withdrawal simulation*. The elevations of the top of the Upper, Middle, and Lower Yorktown-Eastover aquifers at the VAHydroGW-ES cell (row 177, column 35) simulating the greatest drawdown are -86, -155, and -199 feet msl, respectively. Based on the results of the *proposed withdrawal simulation* the predicted potentiometric water levels at the same VAHydroGW-ES cell are -1.1, 6.8, and 7.2 feet msl for the Upper, Middle, and Lower Yorktown-Eastover aquifers, respectively. The 80% drawdown criterion allows the potentiometric water level (based on the critical surface elevation calculated from the VAHydroGW-ES data) to be reduced to -65.5, -120.8, and -156.0 feet msl in the Upper, Middle, and Lower Yorktown-Eastover aquifers, respectively. Therefore, the water levels in the VAHydroGW-ES cells containing the applicant wells for each confined aquifer are not simulated to fall below the critical surface. Additionally, no new VAHydroGW-ES cells are simulated to have water levels

fall below the critical surface. Therefore, this withdrawal is within the limits set by the 80% drawdown criterion.

The requested withdrawal was simulated in the VAHydroGW-ES as allocated 100% to the Upper Yorktown-Eastover aquifer because of the distance within the model to the Exmore paleochannel. The technical evaluation analysis indicated that the apportionment of the requested withdrawal amount among the applicant production wells had no significant effect on the outcome of the technical evaluation.

Water Quality:

The EPA has established the National Secondary Drinking Water Regulations (NSDWRs) which are non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic (such as taste, odor, or color) effects in drinking water. The EPA recommends the secondary standards to water systems – states may choose to adopt them as enforceable standards. The EPA NSDWRs specify the limit on chloride as 250 mg/L.

The VAHydroGW-ES was created "to help the Commonwealth and local water managers better plan water use and estimate future changes in water and salinity levels in response to changes in water use."⁵ Use of the model to predict future chloride concentrations results in a "general useful understanding of system behavior, but water-resource managers must be careful in trusting the accuracy of predictions at individual wells from a regional model."⁶ Further, chloride concentrations at individual wells, predicted using the regional model, should not be relied upon to predict actual concentrations at those locations.

The potential for adverse changes to water quality due to the requested withdrawal was evaluated using transient, density-dependent, SEAWAT simulations using the VAHydroGW-ES. Two simulations were executed – one simulation without the proposed withdrawal included and a second with the proposed withdrawal included. Both simulations were executed for 50 years. And both used the 2017 total permitted stresses, concentrations, and heads as starting conditions. In an effort to simulate the long-term effects on water quality due to the proposed withdrawal, the amount of 11,300,000 gallons per year (30,959 average gpd) was used for the duration of the second simulation. The two simulations were compared to evaluate the potential for adverse changes to water quality. The results indicated that no model cells simulate an increase in chloride concentration greater than 20 mg/L due to the proposed withdrawal. Therefore, the VAHydroGW-ES model results do not indicate the potential for reduced water quality as a result of the proposed withdrawal.

Conclusion:

The withdrawal requested by Hoai An Tran for the Giuse Farm withdrawal satisfies the technical evaluation criteria for permit issuance. The AOIs for the Upper, Middle, and Lower Yorktown-Eastover aquifers are shown in the following maps. The existing permitted wells located within the applicant's AOIs are listed in the following table.

⁵ Sanford, W.E., Pope, J.P., and Nelms, D.L., 2009, Simulation of groundwater-level and salinity changes in the Eastern Shore, Virginia: U.S. Geological Survey Scientific Investigations Report 2009–5066, 125 p.


⁶ Sanford, W.E. and Pope, J.P., 2009, Current challenges using models to forecast seawater intrusion: lessons from the Eastern Shore of Virginia, USA. Hydrogeology Journal (2009), Volume: 18, Issue: 1, p: 73-93

Middle Yorktown-Eastover Aquifer – Existing Permittees within the Giuse Farm AOI

Permittee	Permit	Well	Latitude	Longitude
Van T. Tran	GW0075400	100-01450	37.62338	-75.787944
	GW0075400	100-01451	37.62351	-75.78772
	GW0075400	100-01452	37.624018	-75.788099
	GW0075400	100-01453	37.624134	-75.787928
	GW0075400	100-01454	37.624623	-75.788347
	GW0075400	100-01455	37.624741	-75.788136
	GW0075400	100-01456	37.62543	-75.78834
	GW0075400	100-01457	37.626047	-75.788393
	GW0075400	100-01458	37.626047	-75.78878
	GW0075400	100-01459	37.626149	-75.788607
	GW0075400	100-01460	37.626662	-75.789023
	GW0075400	100-01461	37.626781	-75.788811

Giuse Farm

Area of Impact - Upper Yorktown-Eastover Aquifer



● Giuse Farm Wells

○ Upper Yorktown-Eastover Aquifer Area of Impact

Simulated drawdown at or exceeding one foot in the Upper Yorktown-Eastover aquifer resulting from a 11,300,000 gallons per year (30,959 average gpd), 50 year, Upper Yorktown-Eastover aquifer withdrawal using the VAHydroGW-ES.


Maximum radius of one foot drawdown (Area of Influence) extends approximately 0.8 miles from the pumping center.

Technical evaluation performed by Aquaveo, LLC for the Virginia DEQ, Office of Water Supply
December 14, 2018



Giuse Farm

Area of Impact - Middle Yorktown-Eastover Aquifer



● Giuse Farm Wells

○ Middle Yorktown-Eastover Aquifer Area of Impact

Simulated drawdown at or exceeding one foot in the Middle Yorktown-Eastover aquifer resulting from a 11,300,000 gallons per year (30,959 average gpd), 50 year, Upper Yorktown-Eastover aquifer withdrawal using the VAHydroGW-ES.


Maximum radius of one foot drawdown (Area of Influence) extends approximately 0.8 miles from the pumping center.

Technical evaluation performed by Aquaveo, LLC for the Virginia DEQ, Office of Water Supply
December 14, 2018



Giuse Farm

Area of Impact - Lower Yorktown-Eastover Aquifer



● Giuse Farm Wells

○ Lower Yorktown-Eastover Aquifer Area of Impact

Simulated drawdown at or exceeding one foot in the Lower Yorktown-Eastover aquifer resulting from a 11,300,000 gallons per year (30,959 average gpd), 50 year, Upper Yorktown-Eastover aquifer withdrawal using the VAHydroGW-ES.



Maximum radius of one foot drawdown (Area of Influence) extends approximately 0.8 miles from the pumping center.

Technical evaluation performed by Aquaveo, LLC for the Virginia DEQ, Office of Water Supply
December 14, 2018



SOUTH

NORTH



Coastal Plain (2006) Cross-Sections GS-GS' from USGS Professional Paper 1731.

GUISE FARM - POULTRY FARM WCM PLAN

Introduction

Guise Farm is a contract broiler farm that produces chicken for meat production. The facility consists of 12 chicken houses in the town of Keller in Accomack County, Virginia. The Farm fully understands the need to be a good steward of the region's limited groundwater resources. As a result, key operational and design considerations were made to minimize the use and loss of water in Guise Farm Water Supply System.

This Water Conservation and Management Plan is designed to optimize the Farm groundwater supply and consists of the following elements:

- Practicable Water Saving Equipment and Processes
- Water Loss Reduction Program
- Water Use Education Program
- Evaluation of Practicable Water Reuse Options
- Mandatory Water Use Reductions during Shortages.

Practicable Water Saving Equipment and Processes

The Farm requirements for water saving equipment and processes are implemented primarily through upgrading of equipment and maintenance of the most water efficient poultry houses. Drinker systems for all facilities are designed to provide clean, cool water with adequate flow rate fundamental to food poultry production. The use of closed nipple drinker systems ensures minimal waste of water and precludes the requirement for daily cleaning, which also conserves overall water usage. Flow rates are regularly checked and water consumption is monitored daily with any substantial change in water usage investigated. Evaporative Cooling Pads are utilized only at temperatures above 82° F and recirculate water until evaporated in order to conserve water while still meeting their designed purpose of providing temperature relief in hot conditions for efficient poultry production. The troughs are constructed of corrosion proof, ultraviolet stabilized PVC components to eliminate bacteria and algae growth. Management techniques that do not involve water consumption are also utilized in hot conditions such as walking the birds and feed removal.

The Farm management diligently seeks to save water. The saving of water reduces the electrical cost for running the well pumps, storage tanks, float switch and booster pumps. Management at the Farm will regularly review water consumption electronically and by I-Phone apps which alerts the farmer or staff of any below average or abnormal variations in the system. These variations that are monitored are air, moisture, temperature, and electric power. If the power goes down, there are stand-by diesel- driven generators to be used to provide electric to the houses and wells. Underground water leakage detection can only be determined by spikes in the water meter rates. Once a rate increase is noted or an alert goes out over the cell app, the owner and staff search to discover the location of the leak(s) and repairs begin within the hour after it has been discovered.

GUISE FARM – POULTRY FARM WCM PLAN, PAGE 2

Water Loss Reduction Program

Water Loss Audit

If granted a permit Guise Farm will implement a water audit program within the first 24 months of the permit term. The audit and monthly inspections should eliminate leakage problems by early detection and will be conducted prior to and continue after the audit has been implemented. Annually a water loss audit will be conducted to determine the volume and nature of lost and unaccounted-for water within the water supply system. Audits are conducted on a flock by flock basis once a flock is harvested. The facility is inspected for leaks and broken pipes which can not be detected during the growth period of the chickens. Weekly inspections are made around the facilities pump houses and wells.

Leak Detection and Repair from Distribution System

This farm is monitored on a 24 hours basis by the owner/facility's manager and one or two onsite workers. The houses' cooling and watering systems are inspected and repaired after each flock reaches maturity. All repairs are completed before the next flock comes in. Underground water leakage detection can only be determined by spikes in the water meter rates. Once a rate increase is noted or an alert goes out over the cell app, the owner and staff immediately search to discover the location of the leak(s) and repairs begin within the hour after it has been discovered.

Leak Detection and Repair for Individual Chicken Houses

The Farm staff and management team will pay close attention to abnormal water consumption and if the house controller indicates a higher than normal water requirement, staff and management will come together to find and repair the leaks within the hour after it has been discovered.

Water Use Education Program

Employee Training

All employees on the Guise Farm are encouraged to conserve water and identify potential leaks when hired, during training, and the use of regular conversational reminders and may be required to attend any DPI classes offered. Specifically, employees

GUISE FARM – POULTRY FARM WCM PLAN, PAGE 3

will be instructed in the ways in which they could use less water (or no water) for a given task.

Evaluation of Practicable Water Reuse Options

This is an existing Farm and therefore have limited opportunities to explore water reuse projects for Poultry Farm. The likelihood of a reuse project occurring is remote at this time, given the current water-saving equipment in place and inability to practicably treat collected storm water to standards or quality that can be utilized for flock consumption. The use of nearby surface water would not be sufficient for consumption purposes due to the Water Quality and the possibility of disease found in the local wildlife and waterfowl. The most notable being Bird flu, or Avian Influenza, which can be spread by waterfowl to flocks. These flocks are constantly and carefully immunized to prevent the spread of diseases and to promote healthy birds, and water quality plays a major role in flock health. Should a water use arise that could utilize non-potable water, then a Water Re-use Evaluation will be conducted at that time.

Mandatory Water Use Reductions during Shortages

The facility will comply with all applicable sections of the Accomack County Drought Response and Contingency Plan as identified in the Accomack County Water Supply Plan. This includes voluntary water use restrictions in drought watch and mandatory water use restrictions in a drought emergency. Personnel will be instructed to conserve water and advised of any water use restrictions that may be in place and that the waste of water generally will not be permitted for the duration of a water shortage emergency. Under mandatory water reductions during shortages, it is not feasible to reduce the amount of water which is needed to be provided in order to produce healthy birds.

The only waste water produced by these facilities is the water used to wash off the cooling coils and cooling fans. During emergency water shortages, air may be used to dislodge dust particles from this equipment.

MITIGATION PLAN

DEQ GROUNDWATER WITHDRAWAL PERMIT NO. GW0075800

OWNER NAME: Hoai An Tran

FACILITY FARM: Guise Farm

LOCATION: 16487 Pungoteague Road, Keller Virginia 23401

INTRODUCTION

On April 18,2018, Hoai An Tran submitted a Groundwater Withdrawal Permit Application to the Virginia Department of Environmental Quality (DEQ) to withdraw groundwater. Groundwater withdrawals associated with this permit will be utilized to supply a poultry operation.

The purpose of this Mitigation Plan is to provide existing groundwater users a method to resolve claims that may arise due to the impact of the withdrawal from Guise Farm well field. Predicted drawdown of water levels due to the withdrawal(s) from the Yorktown Eastover-aquifers in use by the facility wells aquifer(s) are shown in the attached maps(s).

Modeled impacts, as shown on the attached maps, extend beyond the boundary of the Guise Farm facility. Due to these findings, Hoai An Tran recognizes that there will be a rebuttable presumption that water level declines that cause adverse impacts to existing groundwater users within the area of impact are due to this withdrawal. Claims may be made by groundwater users outside this area; however, there is a rebuttable presumption that Hoai An Tran/Guise Farm has not caused the adverse impact. Hoai An Tran proposes this plan to mitigate impacts to existing users and excludes impacts to wells constructed after the effective date of this permit.

CLAIMANT REQUIREMENTS

To initiate a claim, the claimant must provide written notification of the claim to the following address:

Contact Name	<u>Hoai An Tran</u>
Title	<u>Owner</u>
Permittee Name	<u>Guise Farm</u>
Address	<u>31040 Seaside Road</u>
City, State Zip Code	<u>Keller Virginia 23401</u>

The claim must include the following information: (a) a deed or other available evidence that the claimant is the owner of the well and the well was constructed and operated prior to the effective date of the permit; (b) all available information related to well construction, water levels, historic yield, water quality, and the exact location of the well sufficient to allow Hoai An Tran to locate the well on the claimant's property; (c) the reasons the claimant believes that the Guise Farm withdrawal has caused an adverse impact on the claimants well(s).

CLAIM RESOLUTION

Hoai An Tran will review any claim within **five (5) business days**. If Hoai An Tran determines that no rebuttal will be made and accepts the claim as valid, Hoai An Tran will so notify the claimant and will implement mitigation within **thirty (30) business days**. If the claim is not accepted as valid, Hoai An Tran will notify the claimant that (a) the claim is denied **or** (b) that additional documentation from the claimant is required in order to evaluate the claim. Within **fifteen (15) business days** of receiving additional documentation from the claimant, (Hoai An Tran) will notify the claimant (a) that Hoai An Tran agrees to mitigate adverse impacts or (b) the claim is denied. If the claim is denied, the claimant will be notified that the claimant may request the claim be evaluated by a three (3) member committee. This committee will consist of one (1) representative selected by Hoai An Tran, one (1) representative selected by the claimant, and one (1) representative mutually agreed upon by the claimant and Hoai An Tran.

Any claimant requesting that a claim be evaluated by the committee should provide the name and address of their representative to Hoai An Tran. Within **five (5) business days** of receipt of such notification, Hoai An Tran will notify the claimant and claimant's representative of the identity of Hoai An Tran representative and instruct the representatives to select a third representative within **ten (10) business days**. Representatives should be a professional engineer or hydrogeologist with experience in the field of groundwater hydrology. Hoai An Tran agrees to reimburse the members of the committee for reasonable time spent, at a rate prevailing in the area for experts in the above listed fields, and for direct costs incurred in administering the plan. The claimant may, at his or her option, choose to provide the reimbursement for the member of the committee selected by the claimant and up to half of the reimbursement for the mutual representative.

Within **ten (10) business days** of selection of the third representative, the committee will establish a **reasonable deadline** for submission of all documentation it needs to evaluate the claim. Both the claimant and Hoai An Tran will abide by this deadline.

Within **fifteen (15) business days** of receipt of documentation, the committee will evaluate the claim and reach a decision by majority vote. The committee will notify the claimant regarding its decision to (a) deny or (b) approve the claim. If the claim is approved, Hoai An Tran will mitigate the adverse impacts within **thirty (30) business days** of making the decision or as soon as practical. If the claim is denied by the committee, Hoai An Tran may seek

reimbursement from the claimant for the claimant's committee representative and one half of the 3rd representative on the committee.

If a claimant within the indicated area of impact indicates that they are out of water, Hoai An Tran will accept the responsibility of providing water for human consumptive needs within **seventy-two (72) hours** and to cover the claim review period. Hoai An Tran reserves the right to recover the cost of such emergency supply if the claim is denied by Hoai An Tran or found to be fraudulent or frivolous. If Hoai An Tran denies a claim and the claimant elects to proceed with the three (3) member committee, Hoai An Tran will continue the emergency water supply at the claimants request during the committee's deliberations, but reserves the right to recover the total costs of emergency water supply in the case that the committee upholds the denial of the claim. Similarly, Hoai An Tran reserves the right to recover costs associated with the claim process if a claim is found to be fraudulent or frivolous.


If it is determined by the committee or shown to the committee's satisfaction that a well operating under a mitigation plan similar to Hoai An Tran/Guise Plan other than those owned and operated by Hoai An Tran has contributed to the claimed adverse impact, Hoai An Tran's share of the costs associated with mitigation will be allocated in proportion to its share of the impact. Such a determination shall be made by the committee after notification of the third party well owner, giving the third party well owner opportunity to participate in the proceedings of the committee.

PLAN ADMINISTRATION

Nothing in the Plan shall be construed to prevent the Department of Environmental Quality Staff from providing information needed for resolution of claims by the committee.

Giuse Farm

Area of Impact - Upper Yorktown-Eastover Aquifer



● Giuse Farm Wells

○ Upper Yorktown-Eastover Aquifer Area of Impact

Simulated drawdown at or exceeding one foot in the Upper Yorktown-Eastover aquifer resulting from a 11,300,000 gallons per year (30,959 average gpd), 50 year, Upper Yorktown-Eastover aquifer withdrawal using the VAHydroGW-ES.


Maximum radius of one foot drawdown (Area of Influence) extends approximately 0.8 miles from the pumping center.

Technical evaluation performed by Aquaveo, LLC for the Virginia DEQ, Office of Water Supply
December 14, 2018



Giuse Farm

Area of Impact - Middle Yorktown-Eastover Aquifer



● Giuse Farm Wells

○ Middle Yorktown-Eastover Aquifer Area of Impact

Simulated drawdown at or exceeding one foot in the Middle Yorktown-Eastover aquifer resulting from a 11,300,000 gallons per year (30,959 average gpd), 50 year, Upper Yorktown-Eastover aquifer withdrawal using the VAHydroGW-ES.


Maximum radius of one foot drawdown (Area of Influence) extends approximately 0.8 miles from the pumping center.

Technical evaluation performed by Aquaveo, LLC for the Virginia DEQ, Office of Water Supply
December 14, 2018



Giuse Farm

Area of Impact - Lower Yorktown-Eastover Aquifer



● Giuse Farm Wells

○ Lower Yorktown-Eastover Aquifer Area of Impact

Simulated drawdown at or exceeding one foot in the Lower Yorktown-Eastover aquifer resulting from a 11,300,000 gallons per year (30,959 average gpd), 50 year, Upper Yorktown-Eastover aquifer withdrawal using the VAHydroGW-ES.

Maximum radius of one foot drawdown (Area of Influence) extends approximately 0.8 miles from the pumping center.

Technical evaluation performed by Aquaveo, LLC for the Virginia DEQ, Office of Water Supply
December 14, 2018



totals for application
greyed out item unlike to be needed, but there just in case

cells requiring entry, if applicable

CONSUMPTION			
(for all houses)			
Max Annual	gal/flock	# flocks/yr	gallons/year
	737,112	5.5	4,054,116
Monthly			
(highest 30 days)			
Day	total gallons-all houses		
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
	or provided		
	0		
	617,112		

COOLING					
if all houses equal size					
tunnel fan capacity	1.6 gpy/1cfm	total cool/house	# of houses	Max annual for cooling	Max mo. for cooling
376,200	1.6	601,920	12	7,223,040	2,407,680
if house size varies					
1-tunnel fan capacity	cfm-cubic feet/min				
cfm/house	# of houses				
		0			
cfm/house	# of houses				
		0			
cfm/house	# of houses				
		0			
cfm/house	# of houses				
		0			
	1.6 gpy/ 1cfm	Max annual for cooling	Max mo. for cooling		
	0	0	0		
	0	1.6	0		

REQUESTED WITHDRAWAL AMOUNTS					
ANNUAL					
Consumption	Cooling	Max Annual	rounded	(nearest 100K)	
4,054,116	7,223,040	11,277,156	11,300,000	manual rounding	
if other usages					
other ag	human	Total Max Annual	rounded	(nearest 100K)	
		11,277,156		manual rounding	
MONTHLY					
Consumption	Max Mo. Cool	Max monthly	rounded	(nearest 100K)	
617,112	2,407,680	3,024,792	3,000,000	manual rounding	
if other usages					
other ag	human	Total Max Mo.	rounded	(nearest 100K)	
		3,024,792		manual rounding	

Giuse Farm
Annual 11,300,000
Monthly 3,000,000

Hoai An Tran Guise Farm

Farm Name: _____

County: ACCOMACK

Permit Application Water Usage Calculations

Facility Information

_____ houses @ 40 ft width

_____ houses @ 50 ft width

_____ houses @ 60 ft width

12 houses @ 66 ft width

_____ flocks per year

Consumption

Attach a farm-specific table of daily water consumption data for one (1) flock. (See attached example table)

Assuming that water consumption remains generally constant from flock to flock, the annual flock consumption may be estimated as follows:

$$\text{Annual Flock Consumption} = \frac{61,426 \text{ gal}}{\text{flock}} \times \frac{5.5 \text{ flock}}{\text{yr}} = \frac{337,843 \text{ gal}}{\text{yr}}$$

$\times \frac{12}{12}$
4'054'116

The maximum monthly flock consumption may be estimated by adding up the daily water consumption for the last 31 days of the flock cycle (typically Days 20-50 of a 50 day flock cycle).

$$\text{Max Monthly Flock Consumption} = \sum_{\text{Day 20}}^{\text{Day 50}} \text{Daily Water Consumption} = \frac{51,426 \text{ gal}}{\text{mo}}$$

$\times \frac{12}{12}$
617'112

Cooling

Per Figure 12 of University of Georgia, Poultry Housing Tips (Evaporative Cooling Pad System Water Usage), Volume 29, Number 1, 2017, the evaporative cooling pad water usage per tunnel fan capacity is estimated as follows:

$$\text{Annual Unit Cooling (Easton, MD)} \approx \frac{160,000 \frac{\text{gal}}{\text{yr}}}{100,000 \text{ cfm}} \approx \frac{1.6 \frac{\text{gal}}{\text{yr}}}{1 \text{ cfm}}$$

Per Page 6 of Cobb-Vantress, Broiler Management Guide, November 15, 2013, the tunnel fan capacity (operating at an airspeed of 600 fpm) may be estimated as follows:

Tunnel Fan Capacity

$$\begin{aligned} &= \left[228,000 \frac{\text{cfm}}{40 \text{ ft width}} \times \text{_____ houses @ 40 ft width} \right] \\ &+ \left[285,000 \frac{\text{cfm}}{50 \text{ ft width}} \times \text{_____ houses @ 50 ft width} \right] \\ &+ \left[342,000 \frac{\text{cfm}}{60 \text{ ft width}} \times \text{_____ houses @ 60 ft width} \right] \\ &+ \left[376,200 \frac{\text{cfm}}{66 \text{ ft width}} \times \underline{12} \text{ houses @ 66 ft width} \right] \\ &= \underline{4'514'400} \text{ cfm} \end{aligned}$$

Given the annual unit cooling and tunnel fan capacity, the annual cooling may be estimated as follows:

$$\text{Annual Cooling} = \underline{4'514'400} \text{ cfm} \times \frac{1.6 \frac{\text{gal}}{\text{yr}}}{1 \text{ cfm}} = \underline{7'223'040} \frac{\text{gal}}{\text{yr}}$$

Requested Withdrawal Amounts

The total annual withdrawal amount may be estimated by adding the annual flock consumption and the annual cooling amounts.

$$\text{Annual Amount} = \frac{4'054'116}{\text{yr}} + \frac{7,223,040}{\text{yr}} = \frac{11,277,156}{\text{yr}}$$

(Note: The handwritten calculation shows 4'054'116 + 7,223,040 = 11,277,156. The original image has some crossed-out numbers and a handwritten '11,277,156' above the result.)

The total monthly withdrawal amount may be estimated by adding the maximum monthly flock consumption amount and one-third of the annual cooling amount (annual cooling divided by 3).

$$\text{Monthly Amount} = \frac{612'112}{\text{mo}} + \left[\frac{7,223,040}{3} \right] = \frac{3,024,792}{\text{mo}}$$

(Note: The handwritten calculation shows 612'112 + (7,223,040 / 3) = 3,024,792. The original image has some crossed-out numbers and a handwritten '3,024,792' above the result.)

↓

2,407,680